

Analytical No. : 3352-006575
Type of sample : Filtered Water
Sample's name : 2. Filtered Drinking Water of Bankeelek School
Container : Sterile Glass Bottle Sealed with Plastic Cap
Temporary label : Sample's Name
Place of sample collection : -

Analytical Result

	Result	Standard	Test method
<u>Microbiological Analysis</u>			
MPN Coliforms / 100 ml	Less than 1.1	Less than 2.2	APHA
<i>E. coli</i> / 100 ml	Not detected	Not detected	APHA
Food-borne Pathogens			
- Salmonellae / 100 ml	Not detected	Not detected	ISO 6340
- <i>S. aureus</i> / 100 ml	Not detected	Not detected	APHA
- <i>C. perfringens</i> / 100 ml	Not detected	Not detected	Compendium (Thailand)

Remark : Use Standard of Bottled Drinking Water, Ministry of Public Health No. 61 (BE 2524)
and No. 135 (BE 2534)



/-5- Analytical No. 3352-006576

The result of analysis is valid for the submitted sample only

THE REPORT IS NOT TO BE USED FOR ADVERTISING PURPOSES