

Analytical No. : 3352-006577
Type of sample : Filtered Water
Sample's name : 2. Filtered Drinking Water of Bannhongyaka School
Container : Sterile Glass Bottle Sealed with Plastic Cap
Temporary label : Sample's Name
Place of sample collection : Near Cafeteria

Analytical Result

	Result	Standard	Test method
<u>Microbiological Analysis</u>			
MPN Coliforms / 100 ml	Less than 1.1	Less than 2.2	APHA
<i>E. coli</i> / 100 ml	Not detected	Not detected	APHA
Food-borne Pathogens			
- Salmonellae / 100 ml	Not detected	Not detected	ISO 6340
- <i>S. aureus</i> / 100 ml	Not detected	Not detected	APHA
- <i>C. perfringens</i> / 100 ml	Not detected	Not detected	Compendium (Thailand)

Remark : Use Standard of Bottled Drinking Water, Ministry of Public Health No. 61 (BE 2524)
and No. 135 (BE 2534)

Analysed by



(Mr. Pongpan Watcharawichanan)

Medical Scientist

The result of analysis is valid for the submitted sample only

THE REPORT IS NOT TO BE USED FOR ADVERTISING PURPOSES